

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7272-0694:200 Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** Fire Control Instruments, 301 2<sup>nd</sup> Avenue, Waltham, MA 02451-1133  
Contact: Anthony J. Shalna (781) 471-3000\*

**DESIGN:** Model 301PL photoelectric smoke detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 8.5 - 32 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Suitable in open areas with air velocities between 0-300 ft/min.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as photoelectric smoke detectors when used in conjunction with separately listed compatible fire alarm control units and Model 301B base (CSFM Listing No. 7300-0694:194). For wall and ceiling mount.

**XLF:** 7272-1209:159

\*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**  
**Program Manager**